



Deepa Enterprises

(Testing Laboratories)

(NABL Approved, Govt. Approved and an ISO: 9001 certified lab)

E-mail: deepa_entp10@yahoo.com, detl.rsv@gmail.com, Website: www.dctl.in

Mob. -8800137739, 9958235476, Tel fax. 0129-2300753



44/11, Adarsh Nagar, Balaji Mandir Road, Ballabgarh, Faridabad (Hr.)-121004

NO-DETL/L/S/18-19/03

Date: 07-01-2019

Letter regarding safe drinking water

It is certified that after testing of sample drinking water by Deepa enterprises (testing laboratories), Issued Test Report no. TC54131800000103P_Dated 31-12-2018 of school **ST. PETER'S SCHOOL**, Sector-16, Faridabad found that safe drinking water w.r.t. mention testing parameter in test certificate for students and members of staff.

Our technical staff Mr. Praveen Kumar Inspect Drinking station location, The Report submitted as per norms reference IS: 10500.

The above valid for a period of 3 month.

Signature with seal

Name : R.S. Vishwkarma

Designation: General Manager



True copy Saritha

PRINCIPAL
ST. PETER'S SCHOOL
SECTOR-16/A
FARIDABAD

MANAGER
ST. PETER'S SCHOOL
SECTOR-16/A
FARIDABAD



DEEPA ENTERPRISES

(Testing Laboratories)

WATER, ENVIRONMENTAL TESTING, ETP, STP, DESIGN, BUILDING & ROAD MATERIAL TESTING LAB.

TEST REPORT

NO. **TC54131900000461**

FARIDABAD: 44/11, ADARSH NAGAR, BALLABGARH-121004, FARIDABAD (HARYANA)

Tel. Fax: 0120-2300753, (M): 8800137730, 9058235476, 9071178062

Email: deepa_entp10@yahoo.com, info.detlindia@gmail.com, detl.rsv@gmail.com Website: www.detl.in

No.-BN8970/7922:0214

DETL/GEN/01/017

Issue Date: 16-04-2019

Request No./Date : 0848

Issue To : **M/s ST. PETER'S SCHOOL**
Sector-16A
Faridabad (Hr.) 121002,India

Date of sample receipt: 13-04-2019

Sample drawn by : DETL

Sample particulars: Drinking water(R/o) from drinking stn Job Order No.: 5760A Sample No.: 5355

TEST RESULTS

Quantity	Container detail	Seal/Unseal	Appearance
2000ml	Plastic bottle	Sealed	Clear
Preservation	Subcontracting	Sampling method	Dev. from std. method
Preserved	NA	IS:3025:Pt.-I	As per Test Method

DATE OF TESTING
13-04-2019 to 16-04-2019

PROTOCOL USED
Reference IS:10500:2012

PARAMETERS	TEST METHOD	RESULTS	UNITS	LIMITS (MAX.)	
				Desirable	Permissible
*Colour	IS: 3025:Pt-4	<5.0	Hazen	5	25
*Odour	IS: 3025:Pt-5	Unobjectionable	Unobjectionable	
*Taste	IS: 3025:Pt-7	Agreeable	Agreeable	
pH value	IS: 3025:Pt-11	6.78	...	6.5 to 8.5	
*Turbidity	IS: 3025:Pt-10	<0.1	NTU	5	10
Total hardness as CaCO ₃	IS: 3025:Pt-21	32.5	mg/l	300	600
Iron (as Fe)	IS: 3025:Pt-53	<0.01	mg/l	0.3	1.0
Chloride(as Cl)	IS: 3025:Pt-32	27.6	mg/l	250	1000
*Residual Free Chlorine	IS: 3025:Pt-26	<0.1	mg/l	0.2Min. When Chlorinated	
Total Dissolved solids	IS: 3025:Pt-16	110.3	mg/l	500	2000
Sulphate (as So ₄)	IS: 3025 Pt-24	<5.0	mg/l	200	400
*Coliform Organism	IS:1622-1981	<1.1	mpn/100ml	2.0	5.0
Conductivity	IS: 3025:Pt-14	169.3	µmoh/cm	-	-

Sample Does Conform to as per IS: 10500 w.r.t. above test results.

- *Not under NABL scope
- *NABL Approved and ISO Certified Lab
- *ISO/IEC/17025:2005 Certified Lab

REMARKS:

True copy *Sunil*

PRINCIPAL

Checked by

Ramma
MANAGER
ST. PETER'S SCHOOL
SECTOR-16/A
FARIDABAD

AUTHORISED SIGNATORY

- Note:
1. Sample will be retained only for one month.
 2. The result listed refer only to the sample and the parameters endorsement of product is neither inferred nor implied.
 3. Total liability of works is limited to the amount paid.
 4. This report cannot be used as evidence in a court of law without written approval of the lab.
 5. Certificate shall not be reproduced except in full, without the written approval of the lab.
 6. Mobile No. for Sample Collection: (M) 9899206224(0) 9958235476

OUR CLIENTS : RAPID METRO, IL&FS, CENTRODOY, GAL INDIAN LTD. NICOM, ELION, ESCORTS, LAKHANI GROUP, SHIVALIK PRINTS GROUP, ADANI, NR SILK, DALTON CABLE, PARAMOUNT, OMAXE, GREEN VALLEY, GYMKHANA, BRIGHT GROUP, PICL, ABHINAV GROUP, PAWNA ZADI, AMAR SHOES, BHOOMI TEXTILE

B. O. : PLOT NO.- 753, SHASTRI NAGAR, BHIKHAMPUR ROAD, DEORIA- 274001, UTTER PRADESH, M. +91 9958288974
: PLOT NO.-148B, LILAWATI ENCLAVE, TIGAON ROAD, BALLABGARH-121004